

APPENDIX D
TEST METHOD CALIBRATION DATA

Omya
Pretest

TRC Environmental Corporation
Critical Orifice Calibration

Date: 10/13/2004 Metering System Identification: 90610 Technician: K. Laakso

Critical Orifice Id No.:		DN-55				DN-63				DN-48			
Critical Vacuum		15				15				15			
K' factor		0.4541				0.569				0.3459			
Run Number		1		2		1		2		1		2	
DGM Final Reading	ft ³	966.054		971.52		978.335		985.149		993.048		1002.355	
DGM Initial Reading	ft ³	959.603		966.054		971.521		978.335		985.149		993.048	
Difference, Vm	ft ³	6.451		5.466		6.814		6.814		7.899		9.307	
Volume Criteria Met	> 5 ft ³	Yes		Yes		Yes		Yes		Yes		Yes	
Inlet/Outlet Temp.													
DGM Initial	°F	72	71	75	71	73	72	74	72	73	72	74	72
DGM Final	°F	75	71	75	72	74	72	75	72	74	72	75	72
Average Temp., Tm		72.25		73.25		72.75		73.25		72.75		73.25	
Time	min.	10.5		9		9		9		17		20	
Delta H	in. H ₂ O	1.1		1.1		1.7		1.7		0.64		0.64	
Pbar	in. Hg	29.78		29.78		29.78		29.78		29.78		29.78	
Ambient Temp.	°F	70		70		70		70		70		70	
Pump Vacuum	in. Hg	16		16		17.5		17.5		19		19	
Vm(std)	ft ³	6.384		5.399		6.747		6.741		7.801		9.183	
Vcr(std)	ft ³	6.168		5.287		6.624		6.624		7.607		8.949	
DGM Cal. Factor, Y		0.966		0.979		0.982		0.983		0.975		0.974	
Y Average		0.973				0.982				0.975			
Y Dev. from avg. ¹		0.67%				0.05%				0.03%			
Y Dev. from other ²		Max Y		0.982		Min Y		0.973		Y deviation		0.99% good	
Delta H@		1.802		1.799		1.772		1.771		1.806		1.804	
Delta H@ Average		1.801				1.772				1.805			
Delta H Dev. from avg. ³		0.09%				0.05%				0.05%			

Average Y =	0.977
Average Delta H =	1.792

- 1 Y at each of the flow rates should not differ by more than +/- 2.0% from the average
- 2 If any critical orifice yields a DGM Y factor differing by more than 2% from others, recalibrate orifices
- 3 Average Delta H@ must be within 0.15 of the average

$$Vm(std) = 17.64 Vm (Pbar + \Delta H/13.6) / (Tm + 460)$$

$$Vcr(std) = K' Pbar Time / \sqrt{Tamb + 460}$$

$$Y = Vcr(std) / Vm(std)$$

TRC Environmental Corporation
Critical Orifice Calibration

*Om yea
Post test*

Date: 5/12/2006 Metering System Identification: 90610 Technician: R. Mennillo

Critical Orifice Id No.:		DN-48				DN-55				DN-63			
Critical Vacuum		15				15				15			
K' factor		0.3476				0.4582				0.5937			
Run Number		1		2		1		2		1		2	
DGM Final Reading	ft ³	530.287	535.919	541.503	548.335	618.287	623.852						
DGM Initial Reading	ft ³	524.654	530.287	535.919	541.503	612.712	618.287						
Difference, Vm	ft ³	5.633	5.632	5.584	6.832	5.575	5.565						
Volume Criteria Met	> 5 ft ³	Yes	Yes	Yes	Yes	Yes	Yes						
Inlet/Outlet Temp.													
DGM Initial	°F	75	74	75	75	75	76	75	75	75	75	75	75
DGM Final	°F	75	75	75	75	75	77	76	75	75	75	75	75
Average Temp., Tm		74.75		75		75.75		75.25		75		75	
Time	min.	12		12		9		11		7		7	
Delta H	in. H ₂ O	0.58		0.58		1.1		1.1		1.8		1.8	
Pbar	in. Hg	29.81		29.81		29.81		29.81		29.81		29.81	
Ambient Temp.	°F	70		70		70		70		70		70	
Pump Vacuum	in. Hg	19.5		19		16		16		16		16	
Vm(std)	ft ³	5.547		5.544		5.496		6.730		5.504		5.494	
Vcr(std)	ft ³	5.401		5.401		5.340		6.526		5.381		5.381	
DGM Cal. Factor, Y		0.974		0.974		0.972		0.970		0.978		0.979	
Y Average		0.974				0.971				0.979			
Y Dev. from avg. ¹		0.03%				0.10%				0.09%			
Y Dev. from other ²		Max Y		0.979		Min Y		0.971		Y deviation		0.82% good	
Delta H@		1.609		1.609		1.753		1.755		1.711		1.711	
Delta H@ Average		1.609				1.754				1.711			
Delta H Dev. from avg. ³		0.02%				0.05%				0.00%			

Average Y =	0.974
Average Delta H =	1.691

- 1 Y at each of the flow rates should not differ by more than +/- 2.0% from the average
- 2 If any critical orifice yields a DGM Y factor differing by more than 2% from others, recalibrate orifices
- 3 Average Delta H@ must be within 0.15 of the average

$$Vm(std) = 17.64 Vm (Pbar + \Delta H/13.6) / (Tm + 460)$$

$$Vcr(std) = K' Pbar Time / \sqrt{Tamb + 460}$$

$$Y = Vcr(std) / Vm(std)$$

*Omga
Pre test*

TRC Environmental Corporation
Critical Orifice Calibration

Date: 3/20/2006 Metering System Identification: 80836

Technician: Evan Bali

Critical Orifice Id No.:		DN 48				DN 55				DN63			
Critical Vacuum		15				15				15			
K' factor		0.3476				0.4582				0.5937			
Run Number		1		2		1		2		1		2	
DGM Final Reading	ft ³	960.212	965.438	971.726	977.729	984.162	990.732						
DGM Initial Reading	ft ³	954.55	960.212	965.741	971.726	977.774	984.162						
Difference, Vm	ft ³	5.662	5.226	5.985	6.003	6.388	6.570						
Volume Criteria Met	> 5 ft ³	Yes	Yes	Yes	Yes	Yes	Yes						
Inlet/Outlet Temp.													
DGM Initial	°F	74	75	75	75	75	76	76	77	76	77	77	78
DGM Final	°F	73	74	74	74	74	74	74	75	75	75	75	75
Average Temp., Tm		74		74.5		74.75		75.5		75.75		76.25	
Time	min.	12.5		11.5		10		10		8		8.5	
Delta H	in. H ₂ O	0.65		0.65		1.2		1.2		1.9		1.9	
Pbar	in. Hg	30.01		30.01		30.01		30.01		30.01		30.01	
Ambient Temp.	°F	69		69		69		69		69		69	
Pump Vacuum	in. Hg	17		17		16		16		16		16	
Vm(std)	ft ³	5.622		5.184		5.942		5.952		6.341		6.516	
Vcr(std)	ft ³	5.669		5.216		5.979		5.979		6.197		6.585	
DGM Cal. Factor, Y		1.008		1.006		1.006		1.004		0.977		1.011	
Y Average		1.007				1.005				0.994			
Y Dev. from avg. ¹		0.12%				0.08%				1.67%			
Y Dev. from other ²		Max Y		1.007		Min Y		0.994		Y deviation		1.35% good	
Delta H@		1.760		1.759		1.868		1.865		1.758		1.756	
Delta H@ Average		1.759				1.866				1.757			
Delta H Dev. from avg. ³		0.05%				0.07%				0.05%			

Average Y =	1.002
Average Delta H =	1.794

- 1 Y at each of the flow rates should not differ by more than +/- 2.0% from the average
- 2 If any critical orifice yields a DGM Y factor differing by more than 2% from others, recalibrate orifices
- 3 Average Delta H@ must be within 0.15 of the average

$Vm(std) = 17.64 Vm (Pbar + \Delta H/13.6) / (Tm + 460)$
 $Vcr(std) = K' Pbar Time / \sqrt{Tamb + 460}$
 $Y = Vcr(std) / Vm(std)$

Onyca
Post test

TRC Environmental Corporation
Critical Orifice Calibration

Date: 5/15/2006 Metering System Identification: 80836 Technician E. Bali

Critical Orifice Id No.:				DN 55			
Critical Vacuum		15		15		15	
K' factor				0.4582			
Run Number		1		2		3	
DGM Final Reading	ft ³	976.506		982.512		988.525	
DGM Initial Reading	ft ³	969.314		976.506		982.512	
Difference, Vm	ft ³	7.192		6.006		6.013	
Inlet/Outlet Temp.							
DGM Initial	°F	72	70	73	71	74	72
DGM Final	°F	73	71	75	72	76	73
Average Temp., Tm		71.5		72.75		73.75	
Time	min.	12		10		10	
Delta H	in. H ₂ O	1.1		1.1		1.1	
Pbar	in. Hg	30.07		30.07		30.07	
Ambient Temp.	°F	70		70		70	
Pump Vacuum	in. Hg	17		17		17	
Vm(std)	ft ³	7.197		5.996		5.992	
Vcr(std)	ft ³	7.182		5.985		5.985	
DGM Cal. Factor, Y		0.998		0.998		0.999	
Y Average				0.998			
Y Dev. from avg. ¹		0.04%		0.02%		0.06%	
Delta H@		1.722		1.718		1.715	
Delta H@ Average				1.718			
H@ Dev. from avg. ²		0.22%		0.02%		0.20%	

Average Y = 0.998
Average Delta H = 1.718

Initial DGM Y = 1.002
Acceptable Cal³ YES

- 1 Y at each of the flow rates should not differ by more than +/- 2.0% from the average
- 2 Average Delta H@ must be within 0.15 of the average
- 3 The post DGM Y calibration has to be within 5% of the initial calibration


$$Vm(std) = 17.64 Vm (Pbar + deltaH/13.6) / (Tm + 460)$$

$$Vcr(std) = K' Pbar Time / SQRT(Tamb + 460)$$

$$Y = Vcr(std) / Vm(std)$$

S-Type Pitot Geometric Calibration Part 1 - Probe Configuration


TRC Probe Identification 4-1
 Technical Specialist R. Mennillo
 Date Dec. 27, 2005



$D_t =$ 0.371

$D_n =$ 0.500


$a =$ 0.921



$P_a =$ 0.489

$P_b =$ 0.489


$b =$ 0.315



$c =$ 4.393

$d =$ 4.016

$e =$ 1.110



$c =$ _____

$f =$ _____

Specifications (EPA Method 2)

$D_t = 3/16"$ to $3/8"$	$c \geq 3"$	$P_a = P_b$
$D_n = 1/2"$	$d \geq 3"$	
$a \geq 3/4"$	$e \geq 3/4"$	$1.05 D_t \leq P \leq 1.50 D_t$
$b \geq 0$	$f \geq 2"$	


If these specifications are met, proceed with Part 2 Pitot alignment.

S-Type Pitot Geometric Calibration Part 2 - Pitot Alignment

TRC Probe Identification 4-1
 Technical Specialist R. Mennillo
 Date Dec. 27,2005

A. Transverse Tube Axis


(80° < Ø < 100°)
 (80° < Ø' < 100°)



a = 0.977
 b = 0.372
 c = 1.034
 d = 0.372
 e = 1.033
 Ø = 88.1
 Ø' = 88.0


B. Longitudinal Tube Axis

(85° < Ø < 95°)
 (85° < Ø' < 95°)




a = 0.977
 b = 0.461
 c = 1.087
 d = 0.461
 e = 1.087
 Ø = 90.9
 Ø' = 90.9

C. (f < 1/8")



D. (g, 1/32")



f = 0
 g = 0

Pitot Calibration = Good

NOTE: Values in parentheses are EPA Method 2 Specifications.

Probe Thermocouple Calibration

Tolerance
 °R = °F + 460

Thermocouple Identification	4-1	°R	% Change Allowable	
Expected Stack Temperature (T _s)		°R		
Reference Thermometer (T _{ref}) boiling pt	<u>672</u>	°R		
Thermocouple Readout	<u>672</u>	°R	0.00%	1.50%
Reference Thermometer (T _{ref}) freezing pt	<u>492</u>	°R		
Thermocouple Readout	<u>493</u>	°R	-0.20%	1.50%

Technician R. Mennillo Date Dec. 27,2005

Reviewed By _____ Date Dec. 27,2005

S-Type Pitot Geometric Calibration Part 1 - Probe Configuration

TRC Probe Identification 4-3
 Technical Specialist R. Mennillo
 Date Dec. 27, 2005

A. D_t = 0.369
D_n = 0.500
a = 0.996

B. P_a = 0.501
P_b = 0.501
b = 0.423

C. c = 4.638
d = 4.452
e = 1.036

OR

D. OR
c = _____
f = _____

Specifications (EPA Method 2)

D _t = 3/16" to 3/8"	c ≥ 3"	P _a = P _b
D _n = 1/2"	d ≥ 3"	
a ≥ 3/4"	e ≥ 3/4"	1.05 D _t ≤ P ≤ 1.50 D _t
b ≥ 0	f ≥ 2"	


If these specifications are met, proceed with Part 2 Pitot alignment.

S-Type Pitot Geometric Calibration Part 2 - Pitot Alignment

TRC Probe Identification 4-3
 Technical Specialist R. Mennillo
 Date Dec. 27, 2005

A. Transverse Tube Axis

($80^\circ < \emptyset < 100^\circ$)
 ($80^\circ < \emptyset' < 100^\circ$)




a = 1.002
 b = 0.330
 c = 1.051
 d = 0.330
 e = 1.053

Ø = 89.3
 Ø' = 89.6

B. Longitudinal Tube Axis


($85^\circ < \emptyset < 95^\circ$)
 ($85^\circ < \emptyset' < 95^\circ$)




a = 1.002
 b = 0.466
 c = 1.111
 d = 0.467
 e = 1.110

Ø = 90.8
 Ø' = 90.6

C. ($f < 1/8"$)



D. ($g, 1/32"$)



f = 0
 g = 0

Pitot Calibration = Good

NOTE: Values in parentheses are EPA Method 2 Specifications.

Probe Thermocouple Calibration

Tolerance
 $^{\circ}\text{R} = ^{\circ}\text{F} + 460$

Thermocouple Identification	<u>4-3</u>	$^{\circ}\text{R}$		
Expected Stack Temperature (T_s)		$^{\circ}\text{R}$	% Change Allowable	
Reference Thermometer (T_{ref}) boiling pt	<u>672</u>	$^{\circ}\text{R}$		
Thermocouple Readout	<u>671</u>	$^{\circ}\text{R}$	0.15%	1.50%
Reference Thermometer (T_{ref}) freezing pt	<u>492</u>	$^{\circ}\text{R}$		
Thermocouple Readout	<u>492</u>	$^{\circ}\text{R}$	0.00%	1.50%

Technician R. Mennillo Date Dec. 27, 2005

Reviewed By _____ Date Dec. 27, 2005